



Postal Address:  
 PO Box 4282  
 Dandenong South, Victoria 3164  
 Australia

Testing. Advising. Assuring.

<b>EWFA CERTIFICATE OF TEST</b>	<b>CERTIFICATE No.: SFC 35506000E.3</b> Page 1 of 1
---------------------------------	---

Report Sponsor	Certificate Issue Date
Boone & Willard Plumbing Pty Unit 13, 5 Meridian Pl. Bella Vista, NSW 2153 And Cooks Plumbing Supplies 27 Loyalty Road North Rocks, NSW 2151	16/10/2015

**Introduction**

The element of construction described below was tested by this laboratory on behalf of the test sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report for more information.

Referenced Report	Test Date	Test Standard
EWFA 35506000.4	15/07/2015	AS 1530.4- 2005

**Description of Service**

The test assembly comprised the following service embedded mid-depth in a nominal 1200mm wide x 1510mm long x 180mm thick concrete slab.  
 The assembly also incorporated a 103mm thick plasterboard wall over the concrete slab and was positioned nominally 150mm back from the service exiting the slab on the exposed side.

ID	Service Name	Encapsulation	Local Fire Protection	Integrity	Insulation
E	Ø20mm EZIPEX	Ø32mm Plastic conduit	Hilti CP 611A	120 minutes	120 minutes

**Notes**

**THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.**

Reference should be made to the relevant test report to determine the applicability of the test result to a proposed installation and for a full description of the tested construction.

The results of these fire tests may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.

<b>TESTING AUTHORITY</b>	Exova Warringtonfire Aus Pty Ltd	
<b>Address</b>	PO Box 4282 DANDENONG SOUTH VIC 3164 Unit 2, 409-411 Hammond Road, DANDENONG VIC 3175	
<b>Phone / Fax</b>	+61 (0) 3 9767 1000 / +61 (0) 3 9767 1001	
<b>ABN</b>	81 050 241 524	
<b>Email / Home Page</b>	<a href="http://www.exova.com">www.exova.com</a>	
<b>Authorisation</b>	Prepared By:  Mandeep Kamal	Reviewed By:  Steven Halliday