

# Promat

## Promat Australia Pty. Ltd.

# SYSTEM CERTIFICATE\*

This is to certify that

## PROMAT Retrofit Fire Protection Collars

For 128mm lightweight partitions and 120mm slab penetrations

have been tested/approved in accordance with

“Australian Standard 1530: Part 4: 2005

Methods for fire tests on building materials, components and structures”

protecting EZI PEX GAS™ pipe penetrations

Retrofit Collar	Pipe	Size (mm)	Wall / Concrete Slab	FRL	Approval no.
PROMASEAL® CFC 32	EZI PEX GAS	16	Concrete Slab	-/240/180	2257301
PROMASEAL® CFC 32	EZI PEX GAS	16	Wall	-/180/180	2257300
PROMASEAL® CFC 32	EZI PEX GAS	20	Concrete Slab	-/240/120	2257301
PROMASEAL® CFC 32	EZI PEX GAS	20	Wall	-/180/60	2257300
PROMASEAL® CFC 32	EZI PEX GAS	25	Concrete Slab	-/240/120	FSP1239
PROMASEAL® CFC 32	EZI PEX GAS	25	Wall	-/180/30	2257300
PROMASEAL® CFC 32	EZI PEX GAS	32	Concrete Slab	-/180/90	2253500
PROMASEAL® CFC 32	EZI PEX GAS	32	Wall	-/180/90	2253502
PROMASTOP® UniCollar	EZI PEX GAS	40	Concrete Slab	-/180/90	2253500
PROMASTOP® UniCollar	EZI PEX GAS	40	Wall	-/180/120	2253502

\* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: [mail@promat.com.au](mailto:mail@promat.com.au)

Visit: [www.promat.com.au](http://www.promat.com.au)

**Head Office**  
**New South Wales Office**  
**Victoria Office**  
**Queensland Office**

1 Scotland Road, Mile End South, SA 5031 AUSTRALIA  
 Unit 1, 175 Briens Road, Northmead, NSW 2152 AUSTRALIA  
 Suite 205, 198 Harbour Esplanade, Docklands, VIC 3008 AUSTRALIA  
 1/68 Lisgar Street, Virginia, QLD 4014 AUSTRALIA

an **etex** company