

Promat

Promat Australia Pty. Ltd.

SYSTEM CERTIFICATE*

This is to certify that

PROMAT Passive Fire Protection Collars

For wall and floor penetrations

have been tested/approved in accordance with

“Australian Standard 1530: Part 4: 2005

Methods for fire tests on building materials, components and structures”

protecting EZI PEX™ pipe penetrations

Retrofit Collar	Pipe	Size (mm)	Wall / Concrete Slab	FRL	Approval no.
PROMASEAL® CFC 32	EZI PEX™	16	Concrete Slab	-/240/120	A-11-737 ⁽¹⁾
PROMASEAL® CFC 32	EZI PEX™	16	Wall	-/180/180	WFRA41195
PROMASEAL® CFC 32	EZI PEX™	20	Concrete Slab	-/180/120	2257301
PROMASEAL® CFC 32	EZI PEX™	20	Wall	-/180/180	2257301
PROMASEAL® CFC 32	EZI PEX™	25	Concrete Slab	-/240/180	A-11-737 ⁽¹⁾
PROMASEAL® CFC 32	EZI PEX™	25	Wall	-/180/180	WFRA21138-01
PROMASEAL® CFC 32	EZI PEX™	32	Concrete Slab	-/240/120	2257301
PROMASEAL® CFC 32	EZI PEX™	32	Wall	-/180/120	A-13-852a

⁽¹⁾ Collar was cast into the slab

* This is NOT a test certificate. For installation instructions or further information please contact Promat Australia Pty. Ltd.

Dial: 1800 PROMAT (776 628)

Email: mail@promat.com.au

Visit: www.promat.com.au

Head Office
New South Wales Office
Victoria Office
Queensland Office

1 Scotland Road, Mile End South, SA 5031 AUSTRALIA
 Unit 1, 175 Briens Road, Northmead, NSW 2152 AUSTRALIA
 Suite 205, 198 Harbour Esplanade, Docklands, VIC 3008 AUSTRALIA
 1/68 Lisgar Street, Virginia, QLD 4014 AUSTRALIA

an **etex** company